



Dow Silicones Corporation
2200 West Salzburg Road
Midland, Michigan 48686
U.S.A.

August 13, 2019

View Incorporated
195 S. Milpitas Blvd
Milpitas, CA 95035

Attention: Thomas Gubiotti

E-Mail: thomas.gubiotti@view.com

Reference: Compatibility testing of Quanex Tri-seal spacer with DOWSIL 982 silicone insulating sealant

Dear: Thomas Gubiotti,

Compatibility testing was completed on 8-6-19 with DOWSIL 982 Silicone Insulating Glass sealant and the Quanex Tri-seal super spacer supplied to Dow Chemical by View Glass. The testing showed no incompatibility between the DOWSIL 982 sealant and the spacer. Please let me know if you have any questions, and thank you for using DOWSIL 982 silicone insulating glass sealant.

Sincerely,
DOW CHEMICAL COMPANY

A handwritten signature in black ink that reads "Michael Brasseur".

Michael Brasseur
Technical Service
Consumer Solutions
The Dow Chemical Company
2200 W. Salzburg Rd., Midland, MI 48686
Phone: 989-496-5403
Cell: 989-859-3925
E-Mail: m.j.brasseur@dow.com

CC: Mike Bott - mike.bott@dow.com